LANDLORD/HOME OWNER GAS SAFETY RECORD Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998.

DR561

Cartificata Deferences



Certifi	cate Ref	ference:	RE	3561													
DETAILS OF THE CONTRACTOR							DETAILS OF THE INSTALLATION					D	DETAILS OF THE CLIENT/LANDLORD				
		Priority Home Service Limited Unit 4, Neepsend Triangle 1 Burton Road Sheffield					Installation Address: Flat 1 Sellars Wheel 106 Arundel Lane Sheffield						Client Address: West One Accomodation (West One) 4 Fitzwilliam Street Sheffield				
		Post Code: S3 8BW						Post Code: S1 4RF						Post Code: S1 4JL			
Gas Safe No:		539093	39093 Telephone No: 0		330 9991999 Tele		elephone No:						Telephone No: 01142722400				
APP	LIANC	E DETAILS															
	Location			A			Make		Model			Flue Type	Landlord's App	oliance Ap	pliance Inspected		
1	Boiler	room	СНВ		llant				Ecotec plus 937 470443		RS	Yes		Yes			
2	N/A		N/A	N/A					N/A		N/A	N/A		N/A			
3	N/A			N/A	N/A			N/A				N/A	N/A		N/A		
4	N/A N/A					N/A	N/A			N/A			N/A	N/A		N/A	
INSPECTION DETAILS												AUDI BLE CO ALARM				M	
	Combu Anal Read	yser in mbai	ror	Safety Devic Correct Oper			Flue and	Condition of Termination sfactory	Flue Performa Test	ince	Appliance Serviced	' İ İ	pliance afe To Use	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactor	
1	0009,9	009,9.46,93 32.32kv		Yes	Ye	Yes		Yes			Yes		Yes	No	N/A	N/A	
2		N/A N/A		N/A		N/A		N/A			N/A		N/A	N/A	N/A	N/A	
3	N/			N/A	N/.			N/A	N/A		N/A	_	N/A	N/A	N/A	N/A	
4	N/	A N/A		N/A	N/.	A	1	N/A	N/A		N/A		N/A	N/A	N/A	N/A	
DEF	ECT(S) IDENTIFIED)				REMEDIAL ACTION TAKEN							NOTICE & LAB			
1 N/A								N/A								N/A	
2 N/A							N/A									N/A	
3 N/A								N/A								N/A	
4	N/A			N/A									N/A				
Outco	me of ga	as installation pipe	cy Contro	Control Valve access satisfactory YES				Οι	Outcome of gas tightness test								
Outco	me of ga	as supply pipework	visual in	nspection	PASS Is the	e Equipote	ipotential bonding satisfactory YES					NEXT INSPECTION DUE ON OR BEFORE: 16/03					
<mark>SI GI</mark>	NATUF	RES Report Issu	ed By:	Name:	Rich Bake	r	Sign	ed:	(5-2	_		Date Ir	nspected:	16/03/2017	Gas ID No	: 3498362	
		Report Rece		Sign	ed:				Date R	eceived:							

Report printed using Tysoft EasyGas - Copyright Tysoft 2016 - Gas Safety (Installation and Use) Regulations 1998

LANDLORD/HOME OWNER GAS SAFETY RECORD CHECK LIST

GUIDANCE FOR RECIPIENT (to be appended to the Certificate)

- 1. Check with the occupant to ascertain any problems with the gas installation and appliance(s).
- 2. Check that there is an adequate supply of air to all gas appliances.
- 3. Check the operation of appliance, control taps, ignition system and any flame supervision devices fitted.
- 4. Check the flame picture of any burner(s).
- 5. Check clearances from combustible materials e.g. kitchen cupboards etc.
- 6. Check the stability of the appliance (including provision of bracket or hook and chain on gas cookers).
- 7. Check gas installation pipe work and where appropriate any flexible connection(s).
- 8. Open-flues

(a) Check the condition and full route (where practicable) of the flue and, where applicable, the suitability of any terminal/chimney pot fitted.

(b) Check the appliance flue connection to any chimney or flue-liner. In the case of a back boiler installation, check all pipe ducts or voids entering the builder's opening including the annular space around any flue liner/flue connection are sealed.

(c) Carry out flue flow check.

(d) For a gas fire, check and clear the catchment space and check that any dampers have been removed or fixed in the open position.

(e) Test the appliance for spillage using any guidance given in the manufacturer's instructions.

9. Room - sealed appliances

(a) Check case and sight glass seal on appliance, replace as necessary.

(b) Check position of terminal, clearances from corners etc. vegetation and terminal guard fitted as appropriate.

- 10. Ensure the operating gas pressure or heat input rate or, where necessary, both are correct.
- 11. Test all controls to ensure satisfactory operation.
- 12. Test all disturbed gas connections for tightness using leak detection fluid, carry out full gas tightness test if required.
- 13. Advise the gas user of any defects/further work required or recommend as necessary.