LANDLORD/HOME OWNER GAS SAFETY RECORD
Safety Inspection and reporting carried out in accordance with the Gas Safety (Installation and Use) Regulations 1998.

Certificate Ref	ference:													
DETAILS OF THE CONTRACTOR						TALLS OF	THE IN	STALLA	TION		DETAILS	OF THE CL	IENT/L	ANDLORD
Trading Title: Address:						stallation ddress: Rented 281a Ecclesall Road Sheffield				Address:	West One Accomodation 281 Ecclesall Road Sheffield		1	
	Post Code: S3 8BW						į	Post Code	: S11 8N	ΝX			Post Code:	S11 8NX
Gas Safe No:	539093	Telepho	ne No: 0330 9	991999	1999 Telepho		e No:				Telephone No: 0114 2134780			
APPLI ANO	CE DETAILS										,			
	Location			Appliance Type			Make	Make		Model		Landlord's App	oliance Ap	pliance Inspected
1 Bed Ro	oom	Ch	Chb			okera		Compact 25 he 4709		25 he 47094	73 RS	Yes		Yes
2 N/A		N/	N/A			/A			N/A		N/A	N/A		N/A
3 N/A			N/A			/A				N/A		N/A		N/A
4 N/A		N/	N/A			/A		N/A			N/A	N/A		N/A
INSPECTION DETAILS											AUDIBLE CO ALARM			M
Comb Anal Read	yser in mbar o	or Sa	afety Devices(s) orrect Operation	Ventilation Pro Satisfactor		Flue and	ondition of Termination factory	Flue Performa Test	nco Ar	ppliance serviced	Appliance Safe To Use	Approved CO alarm fitted	Is CO alarm in date	Testing of CO alarm satisfactor
1 0002,3	2,3.68,8 9mb		Yes Yes			Υ	'es	N/A		No	Yes	Yes	Yes	Yes
2 N/	N/A N/A		N/A N/A			N	I/A	N/A		N/A	N/A	N/A	N/A	N/A
	N/A N/A		N/A N/A			N/A		N/A		N/A	N/A	N/A	N/A	N/A
4 N/	N/A N/A		N/A N/A			N/A		N/A N/A		N/A	N/A	N/A	N/A	N/A
DEFECT(S) IDENTIFIED REMEDIAL ACTION TAKEN													NOTICE & LABE ISSUED	
1 N/A							N/A							N/A
2 N/A						N/A								N/A
3 N/A								N/A						
4 N/A		J/A							N/A					
Outcome of gas installation pipework visual inspection PASS Is the Emergency Control Valve access satisfactory YES Outcome of gas tightness test												PASS		
Outcome of gas supply pipework visual inspection PASS Is the Protective Equipo								etential bonding satisfactory YES				NEXT INSPECTION DUE O9/10.		
<mark>SI GNATUI</mark>	RES Report Issued	d By: Na	ıme:	Rich Baker		Signe	ed:	(5°2		Da	te Inspected:	09/10/2017	Gas ID No	3498362
	Report Receiv	/ed By: Na	ıme:			Signe	ed:			Da	te Received:			
Report printed	using Tysoft EasyGa	s - Copyri	ght Tysoft 2017	' - Gas Safety ((Insta	allation and	Use) Regula	ations 199	98					Page: 1 of

LANDLORD/HOME OWNER GAS SAFETY RECORD CHECK LIST

GUIDANCE FOR RECIPIENT (to be appended to the Certificate)

- 1. Check with the occupant to ascertain any problems with the gas installation and appliance(s).
- 2. Check that there is an adequate supply of air to all gas appliances.
- 3. Check the operation of appliance, control taps, ignition system and any flame supervision devices fitted.
- 4. Check the flame picture of any burner(s).
- 5. Check clearances from combustible materials e.g. kitchen cupboards etc.
- 6. Check the stability of the appliance (including provision of bracket or hook and chain on gas cookers).
- 7. Check gas installation pipe work and where appropriate any flexible connection(s).
- 8. Open-flues
 - (a) Check the condition and full route (where practicable) of the flue and, where applicable, the suitability of any terminal/chimney pot fitted.
 - (b) Check the appliance flue connection to any chimney or flue-liner. In the case of a back boiler installation, check all pipe ducts or voids entering the builder's opening including the annular space around any flue liner/flue connection are sealed.
 - (c) Carry out flue flow check.
 - (d) For a gas fire, check and clear the catchment space and check that any dampers have been removed or fixed in the open position.
 - (e) Test the appliance for spillage using any guidance given in the manufacturer's instructions.
- 9. Room sealed appliances
 - (a) Check case and sight glass seal on appliance, replace as necessary.
 - (b) Check position of terminal, clearances from corners etc. vegetation and terminal guard fitted as appropriate.
- 10. Ensure the operating gas pressure or heat input rate or, where necessary, both are correct.
- 11. Test all controls to ensure satisfactory operation.
- 12. Test all disturbed gas connections for tightness using leak detection fluid, carry out full gas tightness test if required.
- 13. Advise the gas user of any defects/further work required or recommend as necessary.